

ADDENDUM # 1
To the specifications for
REQUEST FOR PROPOSALS (RFP)
FOR DESIGN BUILD SERVICES FOR
HARRY MYERS SPLASH PAD
RFP No.: 2026-003

Purpose of Addendum

This Addendum is issued to (1) clarify certain specifications of the RFP and (2) extend the proposal submittal due date.

Item 1 – Clarification of Specifications

Regarding:

Splash pad floor finish

Clarification:

The splash pad floor finish may consist of brushed concrete with stain incorporated into the concrete mix.

Regarding:

Splash pad electrical

Clarification:

The splash pad electrical shall be 120V, single-phase.

Item 2 – Extension of Due Date

Due to upcoming holidays, the City of Rockwall is extending the RFP submission deadline.

Revised Due Date:
Wednesday, January 7, 2026, at 2:00 p.m. (CST)

All other terms and conditions of the RFP remain unchanged.

Acknowledgment

Please acknowledge receipt of this Addendum by signing below and including a copy with your submittal.

Firm Name

**Authorized
Representative (Print
Name)**

Title

Signature

Date

City of Rockwall

Misty D. Farris

Purchasing Agent

mfarris@rockwall.com

(972) 771-7700